

DECLARATION OF TEST RESULTS

No. 19097C

Non-loadbearing sandwich panel partition wall
type: **REX SDW WALL 1150** – thickness: 200 mm

The element is fully described in test report No. 19097A and classified in classification report No. 19097B.

Obtained test results:

Parameters	Results
Thermal insulation – I	66 minutes
Integrity – E	66 minutes
Radiation – W	66 minutes

Extension of span length (= height)

Until a classification of EI 60, EW 60 and E 60, the span (= height) of the partition may be increased up to 4 m.

This declaration is valid until: 31 May 2021.

WFRGENT NV

European classifications can only be proved with the official classification report No. 19097B according to EN 13501-2.

This document may be used only literally and completely for publications. - For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance. The authenticity of the electronic signatures is assured by Belgium Root CA.