

## Short Form Classification Report No. 17561G

### PRODUCTS

REX SDW WALL 1150 & REX SDW WALL HF 1000

### SPONSOR

REX Panels & Profiles

### PRODUCT PARAMETERS AND FIELD OF APPLICATION (SUMMARY)

- Product as such
  - Coated steel sheets and PIR foam core (40 kg/m<sup>3</sup>)
  - Panel thickness: ≥ 40 mm
  - With metal corner flashes with minimum size of 50 mm x 50 mm x 1 mm
- See the annex on page 2 for the fully detailed field of application and the related product parameters

### CLASSIFICATION

**B-s2,d0**

### STANDARD

For Testing: EN ISO 11925-2:2010/AC 2011 & EN 13823:2010

For Classification: EN 13501-1-2007+A1:2009

#### PREPARED BY



Niek De Pauw (Signature)  
Project assistant  
Ghent  
2016.04.12 15:38:51 +02'00'

#### APPROVED BY



Bart Sette (Signature)  
General Manager  
2016.04.12 16:55:56  
+02'00'

This short form classification report has been drafted according to EGOLF agreement EGA 08rev2:2013 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short form report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2:2010/AC:2011, EN 13823:2010+A1:2014 & EN 13501-1:2007+A1:2009, the presentation of the results in this short form report may not satisfy the requirements of those standards and EN ISO/IEC 17025:2005/AC:2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted.

The full classification report No. **17561F** is available at **REX Panels & Profiles**.

This document is the original version of this report and is written in English. This document may be used only literally and completely for publications. For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.

Page 1 of 2