

DECLARATION OF TEST RESULTS No. 19539B

Loadbearing roof element consisting of composite roof panels
type: **Rex SDW Roof 4** – panel height: 100/135 mm – span length: 3000 mm


The element is fully described in test report No. 19539A.

Obtained test results:

Parameters	Results
Thermal insulation – I	33 minutes
Integrity – E	121 minutes
Loadbearing capacity – R	121 minutes

This declaration is valid until: 12 September 2022.

WFRGENT NV



European classifications can only be proved with the official classification report according to EN 13501-2.

This document may be used only literally and completely for publications. - For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance. The authenticity of the electronic signatures is assured by Belgium Root CA.